HI

From: LCT
Sent: Thursday, March 04, 2004 10:27 AM
To: CCG; CHL; CKC; CKH; CLM; HCH; HI; LCH; LSF; LTC; RO; RW; SC; ST; TWC; YYF
Subject: WATER TURN ON AND CERTIFICATE of SUPERVISION

Please ensure that the plumber enclose a set of the technical detail of the fitting/material when plumber submit "Material List" for QP to endorse. The technical detail must indicate the BS/SS, etc. as required by PUB.

Engineer-in-charge in our office must check that all fitting/material are in accordance with the contract and given No Exception. The Licensed Plumber must sign letter of confirmation for the aforesaid.

Alpha Engineering Consultant

Andrew Loh

Email : LCT@alpha.com.sg

DID : (65)6375 8917

Fax : (65)6276 9929