HI

From: HI
Sent: Wednesday, August 29, 2001 9:49 AM
To: Mechanical
Cc: Loh Chew Thong Andrew; Tan Lai Siong; Teo Kow Kia Richard
Subject: Exemption of Sprinkler Protection

Our Ref: OM-LA/014

29 August 2001

MEMORANDUM

To: Members of the Staff

From: Andrew Loh

EXEMPTION OF SPRINKLER PROTECTION

Further to the memo dated 12 June 2001, please find additional information pertaining to the above.



FSB-Sprinkler Protection.pdf

Regards
Andrew Loh

/hi

SINGAPORE CIVIL DEFENCE FORCE
FIRE SAFETY & SHELTER BUREAU

25A Paterson Road Singapore 238511 Fax: 838 6427
Website: http//:www.mha.gov.sg/scdf

Please quote our ref. no. in all future correspondences

→ FAX To: ACES M&E MEMBERS ONLY (22/8/01)

Our Ref: FSB 34/86

DID: 8386453
FAX: 8386427

ALPHA
23 AUG 2001
FAX RECEIVED

ACES	
President	
Vice-Pres	
Hon. Sec.	
Hon Treas.	
Date Recd	16 AUG 2001
Remarks/Action	Cir. to M/E Only.

13 Aug 2001

Registrar, Board of Architects (BOA)
Registrar, Professional Engineers Board (PEB)
President, Singapore Institute of Architects (SIA)
President, Institute of Engineers, Singapore (IES)
→ President, Association of Consulting Engineers, Singapore (ACES)

Dear Sirs

EXEMPTION OF SPRINKLER PROTECTION

We refer to paragraph 2(a)(iii) of our circular, reference FSB 34/86, dated 6 Jun 2001, which requires cut-off sprinklers to be fitted under the canopy over each of the openings into sprinkler protected building in accordance with clause 6.6.11 of CP52, as one of the conditions to exempt sprinkler protection to areas under canopy.

2. In view of the low hazard risk associated with such areas, taking into consideration that such areas are solely used for purpose of passenger pickup and drop off and there are no commercial activities or storage within these areas, the provision stipulated in paragraph 2(a)(iii) is not applicable with immediate effect. In addition, please note that the dividing wall between the canopy and the building need not be separated by any fire rated wall/partition under such canopy.

3. Please convey the contents of this circular to members of your Institution/Association/Board/Organisation. This circular is also available in our website: http://www.scdf.gov.sg

Yours faithfully

Teo Lim Teck
for Commissioner
Singapore Civil Defence Force

cc: CEO, BCA
All members of FSSB Standing Committee
All members of Fire Code Review Committee
President, REDAS
President, IFE
President, SISV
CEO, HDB
Group President, PSA
CEO, JTC
CE, LTA (Attn: Mr Mohinder Singh)
CE, PSB (Attn: Mr Lau Keong Ong/Ms Tan Chiew Wan)