HI

From: LCT
Sent: Tuesday, August 21, 2007 10:08 AM
To: CCG; CLM; CHL; TCM; CKH; LCH; GWL; KBK; AWL; YYF; LSF; ST; NHS
Cc: HI
Subject: WET RISER SYSTEM FOR HIGH-RISE BUILDING

Ref: OM-LA/019

Have checked with Cpt Han (SCDF) regarding wet riser pump on the building roof without room (to save GFA), it is acceptable provided:

1) Pump, motor, control panel, etc. must be weather proof.

2) Wet riser pump and tank to be 6m away from combustible materials like FRP tank / cooling tower, etc. and 3m away from domestic pump, lift motor room, etc (non-combustible).

3) Accessible only to authorised persons like building management/maintenance staff.

Alpha Consulting Engineers Pte Ltd
Andrew Loh
Email : LCT@alpha.com.sg
DID : (65)6375 8917
Fax : (65)6276 9929