NA OM-LA/111099

From: LCT
Sent: Monday, October 11, 1999 5:52 PM
To: AGH; CCG; CHL; CLM; CTT; HCH; JH; KLT; LSF; LTC; LWC; NHS; NA; NHS; NA; QHN; RW; ST; STH; SYP; THF; TKL; TKL; YYF
Subject: CP29:1998

please be informed that CP29:1998 is now in circulation. a copy of this is available in our library. please takenote of the following changes:

1) hose reel throw shall be 10m at 0.4 l/s. (clause 4.5.1.1)
2) using domestic water storage tank as suction tank for HR is not allow.(clause 4.5.4)
3) emergency power supply shall be provided where available.
4) water supplymay be drawn from the sprinkler system on the supply side of the main stop valve and shall not be more than 50mm dia. (clause 4.5.1.3)

Alpha Engineering Consultant
Andrew Loh
Email : LCT@alpha.com.sg
DID : (65)375 8917
Fax : (65)276 9929