Our Ref: OM-LC/015

9 July 2007

Alpha
Consulting Engineers Pte Ltd

2 ALEXANDRA ROAD, #03-03 DELTA HOUSE, SINGAPORE 159919
TEL: (65) 6276 2228 FAX: (65) 6276 9929 E-MAIL: ace@alpha.com.sg
COMPANY REGISTRATION NO. 199407965N
WEBSITE: www.alpha.com.sg

MEMORANDUM

To: All Engineering Staff

From: Richard Teo

SINGAPORE STANDARD SS 532 : 2007
THE STORAGE OF FLAMMABLE LIQUIDS

Please be informed that we have obtained a copy of SS 532 : 2007 – The Storage of Flammable Liquids and is kept in the Library for reference by the Staff.

RICHARD TEO

cc TLS/LCT / CCG/LFY/GSH
cc Memo File

/kt

BCA
ISO 9000
CERT. NO.: 324
SS ISO 9001 : 2000

Contents

Page

Foreword 7

CLAUSES

1 Scope 9
2 Normative references 9
3 Definitions 10
4 Minor storage 18
5 General requirements for package and tank storage 22
6 Package storage and handling 28
7 Storage in tanks 43
8 Piping and tank auxiliaries 60
9 Operations 63
10 Fire fighting facilities 69

ANNEX

A Tank venting 79

TABLES

1 Hazard precautionary statement 14
2 Minor storage 19
3 Illustration of flammable liquids labelling 27
4 Maximum allowable quantity (MAQ) in m^3 for groups of packages 33
5 Separation distances for groups to protected place (D1)/on-site facility (D2) 34
6 Separation distances for groups to boundary (D3)/fixed ignition sources (S) 34
7 Size of indoor package store based on type of fire protection system 37
8 Separation distances for Category 1, 2, 3 and 4 storage tank capacity more than 3500 m^3 51
9 Separation distances for storage tank capacity less than 3500 m^3 54
10 Foam systems 73
11 Number of fire extinguishers 77
A1 Thermal venting requirements 80
A2 Emergency venting capacity 81
A3 Diameters of free circular openings 82

Page

FIGURES

1	Illustration of site definitions	17
2	Separation distances between minor storages	21
3	Transit storage	24
4(a)	Typical package stores – External detached store without wall	29
4(b)	Typical package stores – External detached store with wall(s)	29
4(c)	Typical package stores – External attached store sharing wall(s)	30
4(d)	Typical package stores – Internal store	30
4(e)	Typical package stores – Fire separated stores	30
5(a)	Stores having opposite external sides open	39
5(b)	Stores having one external side open	39
5(c)	Stores having one external wall with natural vents	39
5(d)	Stores having one external side open and vents in adjacent or opposite external walls	40
5(e)	A store having vents in one pair of opposite external walls	40
6	Illustration of terms relating to various tank locations for all categories	43
7	Illustration of terms relating to various tanks locations for category 4 flammable liquids only	44
8	Bund location limits	53
9	Use of fire wall for reduction of separation distances	55
10(a)	Acceptable layout	55
10(b)	Unacceptable layout	55