Our Ref: OM-LC/022

14 September 2007

Alpha
Consulting Engineers Pte Ltd
2 ALEXANDRA ROAD, #03-03 DELTA HOUSE, SINGAPORE 159919
TEL: (65) 6276 2228 FAX: (65) 6276 9929 E-MAIL: ace@alpha.com.sg
COMPANY REGISTRATION NO. 199407965N WEBSITE: www.alpha.com.sg

MEMORANDUM

To: All Engineering Staff

From: Loh Fook Yuen

SINGAPORE STANDARD CP 19 : 2000
THE INSTALLATION AND MAINTENANCE OF EMERGENCY LIGHTING AND POWER SUPPLY SYSTEMS IN BUILDINGS

Please be informed that we have obtained a copy of CP 19 : 2000 – The Installation and Maintenance of Emergency Lighting and Power Supply Systems in Buildings and is kept in the Library for reference by the Staff.

LOH FOOK YUEN

cc TLS/RT/LCT/CCG/GSH
cc Memo File

/kt

BCA
ISO 9000
CERT. NO.: 324
SS ISO 9001 : 2000

Contents

As amended Mar 2005

Page

Foreword 5

CODE OF PRACTICE

Section One – Installation requirements

1 Scope 6
2 Definitions 6
3 General requirements 8
4 Emergency lighting design requirements 9
5 Emergency power supply (central systems) 20
6 Emergency power supply (single-point systems) 28
7 Provision of discharge test facilities 31
8 Electrical wiring and luminaires 33

Section Two – Maintenance procedures

9 Scope, definitions and general requirements 35
10 Information required for maintaining the systems 36
11 Maintenance procedures for central battery systems 38
12 Maintenance procedures for self-contained emergency luminaires and exit signs 42

ANNEXES

A Classification of emergency luminaires 44
B Diagrams illustrating certain requirements or characteristics of emergency lighting systems 49
C Typical information to be supplied by the purchaser of an emergency lighting system 53
D Guide for the maintenance of batteries and battery chargers 56
E Forms and dimensional details of 'EXIT' signs 57

TABLES

1 Maximum permissible spacing for Class A luminaires 12
2 Maximum permissible spacing for Class B luminaires 13
3 Maximum permissible spacing for Class C luminaires 14
4 Maximum permissible spacing for Class D luminaires 15
5 Maximum permissible spacing for Class E luminaires 16
6 Viewing distances and overall height of graphical symbol signs and 'EXIT' signs – Internally illuminated 18

Page

7 Viewing distances and overall height of graphical symbol signs and 'EXIT' signs – Externally illuminated (including self-luminous signs) 18

8 Chromaticity coordinates for emergency exit signs 19

FIGURES

1 Identification symbol for emergency luminaires 35

2 Vertical planes through emergency luminaires for measurements of luminous intensity 44

3 Characteristic shape of intensity distribution curves for the general classes of emergency luminaire specified in A.3.2.2 47

4 Schematic arrangement of self-contained emergency luminaire (maintained changeover system) 49

5 Schematic arrangement of self-contained emergency luminaire (maintained floating system) 49

6 Schematic arrangement of self-contained emergency luminaire (non-maintained) 50

7 Diagram illustrating sensing and control of emergency lighting (d.c. central system) 50

8 Diagram illustrating sensing and control of emergency lighting (inverter central system) 51

9 Slight-break charger, battery, inverter system 51

10 Slight-break reversible inverter system 52