Alpha
Consulting Engineers Pte Ltd

2 ALEXANDRA ROAD, #03-03 DELTA HOUSE, SINGAPORE 159919
TEL: (65) 6276 2228 FAX: (65) 6276 9929 E-MAIL: ace@alpha.com.sg
WEBSITE: www.alpha.com.sg COMPANY REGN NO. 199407965N

Our Ref: OM-DO/031

19 November 2007

MEMORANDUM

To : Mechanical Engineers & Mechanical CAD

From : Andrew Loh

AMENDMENT TO ENDORSEMENT FOR FSSD SUBMISSION

Please be informed that the above has been amended. For details, please refer to the scanned feedback form in **\Library\Feedback\Forms\100-121107(O).**

ANDREW LOH

cc TLS/RT/CCG/LFY/GSH

enc

KLT/hi

BCA
ISO 9000
CERT. NO.: 324
SS ISO 9001 : 2000

FEEDBACK REPORT FORM

Alpha Engineering Consultant

Ref No: 100 - 121107 (0)

To: ANDREW LOH From: TAY KHYE HAM

Job No./Project: — *(where applicable)*

Source of feedback: FSSD

Scope of Feedback: *Quality System/Administrative/Contractual/Technical/Specification/Others

Section A : Problem & Cause

ENDORSEMENT FOR FSSD SUBMISSION INDICATES
CODE OF PRACTICE FOR FIRE PRECAUTIONS IN BUILDINGS 2002
NEW CODE OF PRACTICE FOR FIRE PRECAUTIONS IN BUILDING TO BE 2007

Section B : Suggested Corrective Action

STANDARD ENDORSEMENT IN AUTOCAD TO BE AMENDED TO YEAR 2007

Section C: Approved Corrective Action

Approved By : Date: 19/11

Section D : Action

Action By: TAY KHYE HAM

Targeted Completion: 12/11/07

Actual Completion: 12/11/07 Verified By:

* *Delete as appropriate*

Distribution:

AMENDED

I, Loh Chew Thong, NRIC No. S0149230F, being a qualified person, hereby certify that the building works and fire safety works as shown on these plans have been designed in accordance with the provisions of the Code of Practice for Fire Precautions in Buildings 2007, including all amendments applicable up to the date of this submission, the Fire Safety Act and its Regulations, the relevant code of practice or designed guidelines, subject to waivers granted under Section 27 of the Act.

I, Loh Chew Thong, hereby certify that

a) The proposed Automatic Fire Sprinkler System has been designed in accordance with the provisions of Code of Practice for Automatic Fire Sprinkler Systems CP 52: 2004
b) The proposed Automatic Fire Alarm System has been designed in accordance with the provisions of Code of Practice for The Installation and Servicing of Electrical Fire Alarm Systems CP 10: 2005
c) The proposed Wet Riser/Dry Riser System has been designed in accordance with the provisions of Code of Practice for Fire Hydrant Systems and Hose Reels CP 29: 1998
d) The proposed kitchen hood extinguisher system has been designed in accordance with NFPA 96 & 17A.

PREVIOUS

I, Loh Chew Thong, NRIC No. S0149230F, being a qualified person, hereby certify that the building works and fire safety works as shown on these plans have been designed in accordance with the provisions of the Code of Practice for Fire Precautions in Buildings 2002, including all amendments applicable up to the date of this submission, the Fire Safety Act and its Regulations, the relevant code of practice or designed guidelines, subject to waivers granted under Section 27 of the Act.

I, Loh Chew Thong, hereby certify that

a) The proposed Automatic Fire Sprinkler System has been designed in accordance with the provisions of Code of Practice for Automatic Fire Sprinkler Systems CP 52:2004
b) The proposed Automatic Fire Alarm System has been designed in accordance with the provisions of Code of Practice for The Installation and Servicing of Electrical Fire Alarm Systems CP 10:2005
c) The proposed Wet Riser/Dry Riser System has been designed in accordance with the provisions of Code of Practice for Fire Hydrant Systems and Hose Reels CP 29:1998
d) The proposed kitchen hood extinguisher system has been designed in accordance with NFPA 96 & 17A.