WaterMark

Level 1

Certificate of Conformity

Australian Certification Services Pty Ltd grants to the WaterMark User:

Oventrop GmbH & Co KG

Trading as F.W. Oventrop GmbH & Co KG

the right to use the WaterMark as shown above in conjunction with the Certificate No. on product/s as identified in the WaterMark Schedule and as listed on the WaterMark database www.abcb.gov.au/Product-Certification/WaterMark-Certification-Scheme which have been shown to comply with the relevant Standard/s and level of certification referred to below. The WaterMark User is granted a licence to use the WaterMark subject to the rules governing the use of the WaterMark.

Product Type:	Recirculation Balancing Valves
Brand:	OVENTROP
Evaluated to:	WMTS 468:2016 Hot water systems—Recirculation valves

Issue Date	25th July 2017
Initial Issue Date:	30th November 2015
Expiry Date:	29th November 2020

Paul Greig
General Manager

Certificate No.: 23230

This certificate remains the property of Australian Certification Services Pty Ltd

WaterMark Level 1 certification is a conformity assessment scheme based on ISO Guide 67 (system 5)

WaterMark

WaterMark Certification Schedule

AUSTRALIAN CERTIFICATION SERVICES

Australian Certification Services Pty Ltd ABN 37 121 022 366
PO Box 627 Jannali, NSW 2226 AUSTRALIA
Phone:+61 2 8521 0726 Email:admin@certificationservices.com.au
www.certificationservices.com.au

JAS-ANZ
www.jas-anz.org/register

Certificate Number: 23230
Issue Date: 25th July 2017
Issue: 01 Revision: 01

The WaterMark User	Oventrop GmbH & Co KG Paul- Oventrop-Strabe 1 Olsberg D-59939 Germany www.oventrop.de
Certificate Number	23156
Level of Certification	WaterMark Level 1
Certification Standards:	WMTS 468:2016 Hot water systems—Recirculation valves

Product Listing

Model Identification	Model Name	Brand Name	Product Description
420 57 04	Aquastrom VT	OVENTROP	DN15 PN16 Thermostatic Recirculation Balancing Valve Metallic (Bronze) Body with Adjustable Temperature Control Range (50-60˚C Factory Set 57˚C) and Adjustable Residual Volume Flow Female Threaded Ends
420 57 06	Aquastrom VT	OVENTROP	DN20 PN16 Thermostatic Recirculation Balancing Valve Metallic (Bronze) Body with Adjustable Temperature Control Range (50-60˚C Factory Set 57˚C) and Adjustable Residual Volume Flow Female Threaded Ends

AUSTRALIAN CERTIFICATION SERVICES

Australian Certification Services Pty Ltd ABN 37 121 022 366
PO Box 627 Jannali, NSW 2226 AUSTRALIA
Phone:+61 2 8521 0726 Email:admin@certificationservices.com.au
www.certificationservices.com.au

www.jas-anz.org/register

Certificate Number: 23230
Issue Date: 25th July 2017
Issue: 01 Revision: 01