Reference Number: CON/C02552/16

Record Of Consultation

Item 1: Enquire about SS575 Cl.1.4.15. Clarify if different components can be procured from different suppliers, and be certified by individual institutions.

Comments: Components may be procured from different suppliers. However, when assembled as one common base, the entire assembly together with an integral or separate fire pump controller, has to be listed and tested by one recognized institution as one common assembly which is certified for use in fire hydrant and wet rising main systems or other fire fighting installations

TEL: 6848 1738 FAX: 6848 1490 EMAIL: Eugene_PHNG@scdf.gov.sg